

FILED FOR RECORD: 11-27-1978 at 4:00 o'clock P M  
DULY RECORDED: 11-28 1978 at 9:00 o'clock A M  
INSTRUMENT NO. \_\_\_\_\_ GRACE BOSTICK, TYLER COUNTY CLK.  
BY Grace Bostick Deputy

TYLER COUNTY COMMISSIONER'S COURT  
SPECAIL MEETING  
NOVEMBER 21, 1978---10:00 A.M.

Vol 4 Pg 870

A Special Meeting of the Commissioner's Court, met on Tuesday November 21, 1978, at 10:00 A.M. All members being present. The meeting was opened with prayer by Commissioner James R. Jordan.

The Bridge on Turkey Creek, HUD project No. B-77-DN-48-0060, having been completed and the Engineer having inspected and certified its completion, a motion was made by Commissioner Jordan and seconded by Commissioner Riley, to release the Contractor's Performance Bond, and the payment Bond be released, pending receipt of contractor affidavit of all bills paid, to Mr. P.B. Seale, Inc. Contractor. All voted yes and none no. See attached.

There being no further business, the meeting adjourned.

SIGNED: Allen Sturrock Allen Sturrock, County Judge  
Maxie Riley Maxie Riley, Comm. Pct. #1  
H.K. Lowe H.K. Lowe, Comm. Pct. #2  
Leon Fowler Leon Fowler, Comm. Pct. #3  
James R. Jordan James R. Jordan, Comm. Pct. #4  
ATTEST: Grace Bostick Grace Bostick, County Clerk





*Vol 4 Pg 871*

ENGINEERING DIVISION

700 NORTH TEMPLE DRIVE DIBOLL, TEXAS 75941 TELEPHONE 713/829-4711

November 17, 1978

The Honorable Allen Sturrock  
County Judge - Tyler County  
100 Courthouse  
Woodville, Texas 75973

RE: Turkey Creek Bridge  
HUD Project No. B-77-DN-48-0060

Dear Judge Sturrock:

On Thursday November 16, 1978 at 2:30 p.m., a final inspection was made on the above referenced project. Present for this inspection were:

Mr. P.B. Seale - P.B. Seale, Inc. - Contractor  
James M. Dunn, P.E. - Temple Associates, Inc. - Engineering Division  
Tom Kelley - Temple Associates, Inc. - Engineering Division

The bridge was found to have been constructed in accordance with the plans and specifications. Appearance and workmanship were excellent and it is recommended that the County make final acceptance of the project. With this in mind, it is further recommended that the contractor's performance bond be released and the payment bond released pending receipt of contractor affidavit of all bills paid.

The contractor requested permission to remove barricades from the project but was instructed to leave them in place until the commissioner was contacted and approval given by him for removal.

It is suggested that the County provide some barricades and warning lights near the bridge until such time the paving is completed. The approaches to the bridge are very slick when wet and could cause some hazard to traffic.

Very truly yours,

TEMPLE ASSOCIATES, INC.

*James M. Dunn*  
James M. Dunn, P.E.  
Civil Department Head

JMD:lm

cc: Semetko & Waxman

